

N323RHT

TEMPERATURE CONTROLLER

USER GUIDE – V2.0x C

1 SAFETY ALERTS

The symbols below are used in the device and throughout this manual to draw the user's attention to valuable information related to device safety and use.

	
CAUTION: Read the manual fully before installing and operating the device.	CAUTION OR HAZARD: Risk of electric shock.

All safety recommendations appearing in this manual must be followed to ensure personal safety and prevent damage to the instrument or system. If the instrument is used in a manner other than that specified in this manual, the device's safety protections may not be effective.

2 SUMMARY

1. SAFETY ALERTS.....	1
2. SUMMARY	1
3. PRESENTATION.....	1
4. SPECIFICATIONS.....	1
4.1 SENSORS: MEASUREMENT ACCURACY AND OPERATING LIMITS	2
4.2 IMPORTANT.....	2
5. ELECTRICAL CONNECTIONS.....	2
5.1 INSTALLATION RECOMMENDATIONS.....	2
6. OPERATION.....	2
6.1 LEVEL 1 – SETPOINT ADJUSTMENT LEVEL	3
6.2 LEVEL 2 – CONFIGURATION LEVEL	3
6.3 LEVEL 3 – CALIBRATION LEVEL	4
7. WORKING WITH THE CONTROLLER.....	5
7.1 OUTPUT TIMING	5
8. CONFIGURATION PROTECTION.....	6
8.1 CONFIGURATION PROTECTION OPERATION	6
9. MASTER PASSWORD.....	6
9.1 HOW TO USE YOUR MASTER PASSWORD	6
10. ERROR INDICATION.....	6
11. WARRANTY	6

3 PRESENTATION

N323RHT is a digital temperature and relative humidity controller. It has 3 relay control outputs. They can be configured independently to act as control or alarms. All outputs can be timed.

The humidity and temperature sensor, sold separately, is protected by a polyamide capsule and has a 3- or 6-meter-long cable.

The details of the controller are in accordance with the purchase order and are shown on the label attached to the controller.

4 SPECIFICATIONS

HUMIDITY SENSOR INPUT:

Measurement range: 0 and 100 % relative humidity (RH) (see Figure 1)

Accuracy: See Figure 1.

Repeatability: ± 1% RH.

Hysteresis: ± 1 % RH.

Linearity error: << 1 % RH.

Stability: < 1 % RH per year.

Response time: Around 8 seconds to reach 63 % of a sudden change in input. Valid for 25 °C at an air flow of 1 m/s.

TEMPERATURE SENSOR INPUT:

Accuracy: See Figure 2.

Repeatability: ± 0.1 °C.

Measurement range: -20 and 100 °C.

Response time: Up to 30 seconds with softly moving air.

Warm-up time: 15 minutes.

Measurement resolution:

RH: 1 % over the entire range.

T: 0.1° from -20 to 100°.

Note: The equipment maintains accuracy over the entire range, although the low resolution of the display in a portion of the range does not allow it to be visualized.

OUTPUT1: SPDT relay; 1 HP 250 Vac / 1/3 HP 125 Vac (16 A Res.).

Optionally: Pulse, 5 Vdc, 25 mA maximum.

OUTPUT 2: Relay: 3 A / 250 Vac, SPST-NO.

OUTPUT 3: Relay: 3 A / 250 Vac, SPST-NO.

POWER SUPPLY:

Voltage: 100~240 Vac/dc 10 %.

Optionally: 24 V (12~30 Vdc) (*).

Frequency: 50~60 Hz.

Consumption: 5 VA.

(* **Note:** Models with a 24 V power supply do not have electrical isolation between the power supply, input, and RS485 communication circuits.

In direct current (Vdc) supply networks, you must observe the polarity of the connection.

Dimensions:

Width x Height x Depth: 75 x 33 x 75 mm.

Panel cutout: 70 x 29 mm.

Weight: 100 g.

Operating environment of the electronic module: 0 to 40 °C / 20 to 85 % RH.

Operating environment of the sensor module: -20 to 100 °C / 0 to 100 % RH.

UL94 V-2 Polycarbonate housing.

Protection index: Housing: IP42 | **Front:** IP65 | **Sensor housing:** IP40 (sold separately).

Connections for wires up to 4.0 mm².




RS485 interface with Modbus protocol (optional).

Certifications: CE, UL.



The RS485 interface (when available on the controller) is **NOT** electrically isolated from the input circuit.
It is also **NOT** isolated from the power supply circuit in 24V power supply models (12~24 Vdc).

4.1 SENSORS: MEASUREMENT ACCURACY AND OPERATING LIMITS



4.2 IMPORTANT

The sensor used in this equipment can be damaged or lost calibration if exposed to atmospheres contaminated with chemical agents.

Hydrochloric Acid, Nitric Acid, Sulfuric Acid, and Ammonia in high concentrations can damage the sensor. Acetone, Ethanol, and Propylene Glycol can cause reversible measurement error.

Corrections to any errors detected during sensor readings can be made directly in the controller, using parameters **DFH** and **DFE**, within the configuration level.

5 ELECTRICAL CONNECTIONS

The following figure shows the connection, power, and output terminals of the controller:




Figure 4

5.1 INSTALLATION RECOMMENDATIONS

- Input signal conductors should run through the plant separate from output and supply conductors. If possible, in grounded conduits.
- The power supply for electronic instruments must come from a network specific to the instrumentation.
- It is recommended to use RC FILTERS (noise suppressors) in contactor coils, solenoids, etc.

6 OPERATION

Before use, the controller must be configured. To configure it, you must set values for the parameters that determine how the equipment operates.

These configuration parameters are organized in groups or Levels, called Parameter Levels.

LEVEL	RELATED FUNCTIONS
0	Temperature measurement
1	Setpoint adjustment
2	Configuration
3	Calibration

Table 1

When the controller is turned on, the display will show the version of the internal software. This information is important for any contact with the manufacturer. The controller will then start operating and display the environment's temperature value, measured by sensor 1. This is level **0** or the Temperature Measurement level.

To access level 1, press **P** for **1 second**, until **SP 1** parameter is displayed. Release the **P** key to remain at this level. To return to the Temperature Measurement level, press **P**.

To access level 2, press **P** for 1 seconds, until **rHE** parameter is displayed. Release the **P** key to remain at this level. To access the other parameters of this level, press **P** again. After the last parameter, the equipment will return to the Temperature Measurement level.

To change the parameter values, use the **▲** and **▼** keys.

Notes:

- 1 When you move from one parameter to another, the configuration will be saved automatically and only then considered valid. Even in the event of a power outage, the configuration is stored in permanent memory.
- 2 If the keys are not used for a time longer than 20 seconds, the equipment returns to the Measurement level, finishing and saving the configuration done so far.

6.1 LEVEL 1 – SETPOINT ADJUSTMENT LEVEL

This level displays only the Setpoint parameter (SP). It sets the desired humidity or temperature value for the system. The current SP value is shown alternately with the parameter value.

To set the desired value, use the and keys.

SP 1 <i>Setpoint 1</i>	Set the desired temperature for control output 1. This adjustment is limited to the values programmed in SL 1 and SH 1 .
SP 2 <i>Setpoint 2</i>	Set the desired temperature for control output 2. This adjustment is limited to the values programmed in SL 2 and SH 2 .
SP 3 <i>Setpoint 3</i>	Set the desired temperature for control output 1. This adjustment is limited to the values programmed in SL 4 and SH 3 .

6.2 LEVEL 2 – CONFIGURATION LEVEL

It displays the sequency of parameters that must be defined. The parameters are shown alternately with their values.

To set the desired values, use the and keys.

rHt <i>RH - Temp</i>	Allows you to define how the humidity and temperature variables will be shown on the display: <ul style="list-style-type: none"> 0 Humidity. 1 Temperature. 2 Alternates between humidity and temperature every 2 seconds. 3 Alternates between humidity and temperature every 3 seconds. 4 Alternates between humidity and temperature every 4 seconds. 5 Alternates between humidity and temperature every 5 seconds. For options 0 and 1 : By quickly pressing the P key, the controller displays the value of the other variable for 10 seconds.
Unit <i>Unit</i>	Allows you to select the display unit of the measured temperature: <ul style="list-style-type: none"> 0 Temperature in Celsius degrees. 1 Temperature in Fahrenheit degrees.
DFH <i>Offset Humidity</i>	Value to correct humidity indication. Allows you to make small adjustments to the relative humidity indication to correct measurement errors that appear, for example, when replacing the temperature sensor. Adjustable between -10.0 and 10.0. Normally, it should remain at 0.0.
DFt <i>Offset temperature</i>	Value to correct temperature indication. Allows you to make small adjustments to the temperature indication to correct measurement errors that appear, for example, when replacing the temperature sensor. Adjustable between -10.0 and 10.0. Normally, it should remain at 0.0.

SL 1 <i>SP Low Limit 1</i>	Setpoint 1 (SP 1) lower limit. Minimum value that can be set for Setpoint 1. It must be programmed with a lower value than the one programmed in SH 1 .
SH 1 <i>SP High Limit 1</i>	Setpoint (SP 1) upper limit. Maximum value that can be set for Setpoint 1. It must be programmed with a higher value than the one programmed in SH 1 .
SL 2 <i>SP Low Limit 2</i>	Setpoint 2 (SP 2) lower limit. Minimum value that can be set for Setpoint 2. It must be programmed with a lower value than the one programmed in SH 2 .
SH 2 <i>SP High Limit 2</i>	Setpoint (SP 2) upper limit. Maximum value that can be set for Setpoint 2. It must be programmed with a higher value than the one programmed in SL 2 .
SL 3 <i>SP Low Limit 3</i>	Setpoint 3 (SP 3) lower limit. Minimum value that can be set for Setpoint 3. It must be programmed with a lower value than the one programmed in SH 3 .
SH 3 <i>SP High Limit 3</i>	Setpoint (SP 3) upper limit. Maximum value that can be set for Setpoint 3. It must be programmed with a higher value than the one programmed in SL 3 .
AC 1 <i>Action 1</i>	Control action for OUTPUT 1: <ul style="list-style-type: none"> 0 Control with Reverse Action. For heating and humidification. 1 Control with Direct Action. For refrigeration and dehumidification (*). 2 Minimum alarm. 3 Maximum alarm. 4 Minimum alarm with Initial Block. 5 Maximum alarm with Initial Block.
AC 2 <i>Action 2</i> AC 3 <i>Action 3</i>	Control action for OUTPUT 2 and OUTPUT 3: <ul style="list-style-type: none"> 0 Control with Reverse Action. For heating and humidification. 1 Control with Direct Action. For refrigeration and dehumidification (*). 2 Minimum alarm. 3 Maximum alarm. 4 Minimum alarm with Initial Block. 5 Maximum alarm with Initial Block. 6 Within-range alarm. 7 Out-of-range alarm. 8 Within-range alarm with Initial Block. 9 Out-of-range alarm with Initial Block. 10 Cycle timer (only available for AC 3). See the WORKING WITH THE CONTROLLER section, where these functions are detailed.
Cnt <i>Control</i>	Allows you to define the layout of the outputs: <ul style="list-style-type: none"> 0 OUTPUT 1 = Humidity OUTPUT 2 = Humidity OUTPUT 3 = Humidity 1 OUTPUT 1 = Humidity OUTPUT 2 = Humidity OUTPUT 3 = Temperature

	<p>2 OUTPUT 1 = Humidity OUTPUT 2 = Temperature OUTPUT 3 = Humidity</p> <p>3 OUTPUT 1 = Humidity OUTPUT 2 = Temperature OUTPUT 3 = Temperature</p> <p>4 OUTPUT 1 = Temperature OUTPUT 2 = Humidity OUTPUT 3 = Humidity</p> <p>5 OUTPUT 1 = Temperature OUTPUT 2 = Humidity OUTPUT 3 = Temperature</p> <p>6 OUTPUT 1 = Temperature OUTPUT 2 = Temperature OUTPUT 3 = Humidity</p> <p>7 OUTPUT 1 = Temperature OUTPUT 2 = Temperature OUTPUT 3 = Temperature</p>
<p>HY 1 HY 2 HY 3 Hysteresis</p>	<p>Control hysteresis. Differential between the on and off point of the control output relay. Adjustable between 0.1 and 50.0.</p>
<p>dL 1 dL 2 dL 3 Delay</p>	<p>Delay to the start of control. Once the controller is turned on, the output (1, 2, or 3) will only be turned on after the time programmed in this parameter has elapsed. Used in large refrigeration systems to prevent compressors from being activated simultaneously during a power outage. Value in seconds. From 0 to 250 seconds.</p>
<p>(*) OF 1 OF 2 OF 3 Off time</p>	<p>Level available when AC 1, AC 2, and AC 3 are set to 1. Allows you to set the minimum off time for the output. When the output is turned off, it will remain in this condition for at least the time programmed in this parameter. Typically used to extend the lifespan of the compressor in a refrigeration system. For heating applications, set to 0. Value in seconds. From 0 to 999 seconds.</p>
<p>(*) On 1 On 2 On 3 on time</p>	<p>Level available when AC 1, AC 2, and AC 3 are set to 1. Allows you to set the minimum on time for output 1. When the output is turned on, it will remain in this condition for at least the time programmed in this parameter. Typically used to extend the lifespan of the compressor in a refrigeration system. For heating applications, set to 0. Value in seconds. From 0 to 999 seconds.</p>
<p>1E 1 OUTPUT1 T1</p>	<p>T1 time interval for timing output 1 (OUTPUT1). Allows the timed actuation of the outputs to be defined, as shown in Table 2. Adjustable between 0 and 1999 seconds. Parameter not available when outputs are configured for Direct Action.</p>
<p>2E 1 OUTPUT2 T1</p>	<p>T1 time interval for timing output 2 (OUTPUT2). Allows the timed actuation of the outputs to be defined, as shown in Table 2. Adjustable between 0 and 1999 seconds. Parameter not available when outputs are configured for Direct Action.</p>

<p>3E 1 OUTPUT3 T1</p>	<p>T1 time interval for timing output 3 (OUTPUT3). Allows you to set the timed actuation of the outputs, as shown in Table 2. Adjustable between 0 and 1999 seconds (*). Parameter unavailable when output 3 is configured for Direct Action. (* If AC 3 is configured as a Cycle Timer (10), 3E 1 will now represent the duration of the interval with the output on and the value set will be shown in MINUTES. See Figure 3. Timer output trigger duration.</p>
<p>1E 2 OUTPUT1 T2</p>	<p>T2 time interval for timing output 1 (OUTPUT1). Allows the timed actuation of the outputs to be defined, as shown in Table 2. Adjustable between 0 and 1999 seconds. Parameter not available when outputs are configured for Direct Action.</p>
<p>2E 2 OUTPUT2 T2</p>	<p>T2 time interval for timing output 2 (OUTPUT2). Allows the timed actuation of the outputs to be defined, as shown in Table 2. Adjustable between 0 and 1999 seconds. Parameter not available when outputs are configured for Direct Action.</p>
<p>3E 2 OUTPUT3 T2</p>	<p>T2 time interval for timing output 3 (OUTPUT3). Allows you to set the timed actuation of the outputs, as shown in Table 2. Adjustable between 0 and 1999 seconds (*). Parameter unavailable when output 3 is configured for Direct Action. (* If AC 3 is configured as a Cycle Timer (10), 3E 1 will now represent the duration of the interval with the output on and the value set will be shown in MINUTES. See Figure 3. Timer output trigger duration.</p>
<p>Rdr Address</p>	<p>Controllers with RS485 serial communication interface display the Rdr parameter. In this parameter, you can define a communication address for each network element. The address defined must be between 1 and 247.</p>

Note: The use of the delay between compressors (**dL 1** and **dL 2**) ensures that, when returning from a power failure or during system start-up, the compressors are started one by one, according to the set timing. This reduces the energy demand at that time.

6.3 LEVEL 3 – CALIBRATION LEVEL

The controller leaves the factory already calibrated. When a recalibration is necessary, it must be performed by a specialized professional.

To access this level, press the **P** key for more than 3 seconds. This level also contains the protection and formatting parameters of the controller.

If you access it by accident, simply step through all parameters, until the controller returns to the Measurement Level.

<p>PA5 Password</p>	<p>Allows you to enter a password to enable changes to other parameters.</p>
<p>rCL RH Calibration Low</p>	<p>Relative humidity Offset calibration.</p>
<p>tCL T Calibration Low</p>	<p>Temperature Offset calibration.</p>
<p>PrE Protection</p>	<p>Allows you to set the parameter levels to be protected.</p>

PA Password Change	Allows to change the current password. You can set the password to a number between 1 and 999.
Sn2 Serial Number 2	Displays the first 2 digits of the electronic serial number of the controller.
Sn1 Serial Number 1	Displays the middle 3 digits of electronic serial number of the controller.
Sn0 Serial Number 0	Displays the last 2 digits of the electronic serial number of the controller.

7 WORKING WITH THE CONTROLLER

The controller acts on the OUTPUT1, OUTPUT2, and OUTPUT3 outputs to bring the measured variable (temperature or humidity) to the desired value, set by the Setpoint (SP1, SP2, and SP3).

OUTPUT 1, OUTPUT 2, and OUTPUT 3 can act as control outputs when they act directly on the system load (resistance, compressor, humidifier etc.) or they can act as alarm outputs, which signal the occurrence of a specific situation defined by the user.

The actuation modes are shown below and can be set in parameters AC1, AC2, and AC3.

0 Control output with Reverse Action.

Turns the output on when the measured variable is below the Setpoint assigned to this output.

Type of action used for heating control

1 Control output with Direct Action.

Turns the output on when the measured variable is above the Setpoint assigned to this output.

Type of action used for refrigeration control

2 Minimum alarm.

Turns the output on when the measured variable is below the Setpoint assigned to this output.

3 Maximum alarm.

Turns the output on when the measured variable is above the Setpoint assigned to this output.

4 Minimum alarm with Initial Block.

Same as the Minimum Alarm + the Initial Block feature, as described in the note below

5 Maximum alarm with Initial Block.

Same as the Maximum Alarm + the Initial Block feature, as described in the note below

6 Within-range alarm.

Turns the output on when the measured variable is within the range defined in the figure below:

$$(SP1 - SP2) \text{ and } (SP1 + SP2)$$

$$\text{or } (SP1 - SP3) \text{ and } (SP1 + SP3)$$

7 Out-of-range alarm.

Turns the output on when the measured variable is outside the range defined in the figure below:

$$(SP1 - SP2) \text{ and } (SP1 + SP2)$$

$$\text{or } (SP1 - SP3) \text{ and } (SP1 + SP3)$$

8 Within-range alarm with Initial Block.

Same as the Alarm Within Range + the Initial Block feature, as described in the note below

9 Out-of-range alarm with Initial Block.

Same as the Alarm Out of Range + the Initial Block feature, as described in the note below

10 Operation as a Cycle Timer

Option only available for configuring OUTPUT 3 (AC3). It configures OUTPUT3 to operate as a cyclic timer, independent of temperature or humidity control.

Parameters 3E1 and 3E2 define the time intervals at which OUTPUT 3 remains on and off, respectively.

In this option, parameters 3E1 and 3E2 will be set in MINUTES.




Figure 5

Note: Actuation modes 6, 7, 8, and 9 are only available for OUTPUT 2 and OUTPUT 3.

For OUTPUT 2, when AC is set to 0, 1, 6, or 7.

For OUTPUT 3, when AC is set to 0, 2, 5, or 7.

Note: Initial Block makes the controller disregard alarm situations at the beginning of the process when the controller is switched on and starts control operation.

Initial Block prevents (blocks) the alarm from being switched on at the beginning of the control process. The alarm will only be unblocked once the measured variable has passed through a non-alarm condition. This feature is useful, for example, when a minimum alarm is programmed into a heating process. Without blocking, the process would start with the alarm activated until the control Setpoint was reached.

7.1 OUTPUT TIMING

The controller allows you to program the timing of the outputs. Three conditions can be established:

1. Delayed output activation
2. Temporary activation
3. Sequential activation

Timing is only available for outputs 1, 2, and 3 and is programmed using parameters 1E1, 2E1, 3E1, 1E2, 2E2, and 3E2. The figures below represent these functions.

T1 and T2 can vary from 0 to 1999 seconds and their combinations determine the timing mode.

If you want the alarms to operate normally, without timers, set 0.

On the frontal panel, P1, P2, and P3 flags light up when the respective outputs are triggered. During the delay, the respective flag will remain flashing.

TIMER FUNCTION	T1	T2	PERFORMANCE
Normal operation	0	0	Alarm Output: Immediate activation after Alarm Event.
Delayed activation	0	1 to 1999 s	Alarm Output: Delayed activation after Alarm Event (T2).
Temporary activation	1 to 1999 s	0	Alarm Output: Temporary activation after Alarm Event (T1).
Sequential activation	1 to 1999 s	1 to 1999 s	Alarm Output: Sequential activation after Alarm Event (T1, T2, T1).

Table 2

8 CONFIGURATION PROTECTION

The configuration protection system prevents undue changes to the parameters of the controller and, consequently, its operating mode.

This system is composed of parameters that define the degree of protection to be adopted (full or partial).

Parameters that define the protection:

PRS Allows you to enter a password to enable changes to other parameters.

PrL Allows you to set the parameter levels to be protected:

1. Only **Calibration** level is protected (factory configuration).
2. **Calibration** and **Configuration** levels are protected.
3. All levels are protected: **Calibration**, **Configuration**, and **SP**.

PRC Allows you to change the current password. You can set the password to a number between 1 and 999.

8.1 CONFIGURATION PROTECTION OPERATION

The **PRS** parameter appears at the beginning of the protected level.

If you enter the password correctly, it is possible to change the parameters of the protected levels. If you do not enter the password correctly or simply pass by this parameter, the parameters of the protected levels can only be viewed.

Notes:

1. When you enter an incorrect password 5 consecutive times, the equipment will prevent new attempts for 10 minutes. If you do not remember the current password, you can enter the **master password**, which only allows you to set a new password.
2. When the equipment leaves the factory, the password is set to 111.

9 MASTER PASSWORD

The master password, which allows you to set a new password for the controller, uses the serial number of the equipment (**Sn2**, **Sn1**, and **Sn0**). It is composed as follows:

$$[1] + [\text{largest number of Sn2}] + [\text{largest number of Sn1}] + [\text{largest number of Sn0}]$$

The master password for an equipment with serial number 97123465 is: **1 9 3 6**

Example: **Sn2** = 97; **Sn1** = 123; **Sn0** = 465 = 1 + 9 + 3 + 6

9.1 HOW TO USE YOUR MASTER PASSWORD

1. In the **PRS** parameter, enter the master password.
2. In the **PRC** parameter, enter any new non-zero (0) password.
3. Use the new password.

10 ERROR INDICATION

On the display, the controller shows messages that correspond to problems related to humidity measurement. Whenever they are displayed, the control output relay will be turned off immediately.

	Indicates that the measurement has exceeded the upper limit of the sensor's range. The sensor is malfunctioning.
	Indicates that the measurement has exceeded the lower limit of the sensor's range. The sensor is malfunctioning.
	Sensor problem. Check the connections between the sensor and the controller. If the problem persists, contact technical assistance.

Table 3

11 WARRANTY